

Zertifikat

Certificate



Zertifikat Nr. Certificate No.
R 50429501

Blatt Sheet
0001

Ihr Zeichen Client Reference	Unser Zeichen Our Reference	Ausstellungsdatum Date of Issue	Date of Issue
W.D.S.	01-SYF-15090231 012	20.09.2019	(day/mo/yr)

Genehmigungsinhaber License Holder	Fertigungsstätte Manufacturing Plant
WUXI SUN KING ENERGY TECHNOLOGY CO., LTD. 408, Block C, No.4 Longshan Road, Xinwu District, Wuxi, Jiangsu P. R. China	030-0000426013

Prüfzeichen Test Mark



Type Approved
Safety
Regular Production
Surveillance

www.tuv.com
ID 1419066220

Geprüft nach Tested acc. to
EN 50618:2014

Zertifiziertes Produkt (Geräteidentifikation)
Certified Product (Product Identification)

Lizenzentgelte - Einheit
License Fee - Unit

PV-Cables (Electric Cables for Photovoltaic Systems)

Type Designation : H1Z2Z2-K 1X4...6mm² 6
WUXI SUN KING ENERGY TECHNOLOGY CO., LTD.

Rated Voltage : DC 1,5kV
AC 1,0/1,0kV

Ambient Temperature : -40°C to +90°C

Max. Temperature at Conductor : 120°C

6

Dem Zertifikat liegt unsere Prüf- und Zertifizierungsordnung zugrunde und es bestätigt die Konformität des Produktes mit den oben genannten Standards und Prüfgrundlagen. Zusätzliche Anforderungen in Ländern, in denen das Produkt in Verkehr gebracht werden soll, müssen zusätzlich betrachtet werden. Die Herstellung des zertifizierten Produktes wird überwacht.
This certificate is based on our Testing and Certification Regulation and states the conformity of the product with the standards and testing requirements as indicated above. Any additional requirements in countries where the product is going to be marketed have to be considered additionally. The manufacturing of the certified product is subject to surveillance.

TÜV Rheinland LGA Products GmbH, Tillystraße 2, 90431 Nürnberg

Tel.: +49 221 806-1371 e-mail: cert-validity@de.tuv.com
Fax: +49 221 806-3935 http://www.tuv.com/safety

Zertifizierungsstelle



Bo Liu